

| School ID | Sample Name | Sample Type | First Round Sampling Date (No Pre-Stagnation Flushing, Followed by Initial First Draw Sample) | First Round Results (ppb) (ppb = µg/L) | Sample Name | Second Round Sampling Date (1 hour Flushing, Followed by Initial First Draw Sample) | Second Round Results (ppb) (ppb = µg/L) |
|-------------------------|---------------------|----------------------------------|--|---|----------------------|---|--|
| AG Wright | AWM-BS-GLR | Bathroom Sink | 8/14/2017 | 29.50 | AWM2-BS-GLR | 9/1/2017 | 13.90 |
| AG Wright | AWM- CF-M13 | Classroom Fountain | 8/14/2017 | 25.80 | AWM2-CF-M13 | 9/1/2017 | 1.89 |
| AG Wright | AWM- CF-M14 | Classroom Fountain | 8/14/2017 | 24.50 | AWM2-CF-M14 | 9/1/2017 | 1.80 |
| AG Wright | AWM-CF-1FL-M12 | Classroom Fountain | 8/14/2017 | 18.40 | AWM2-CF-1FL-M12 | 9/1/2017 | 5.63 |
| AG Wright | AWM- CF-M24 | Classroom Fountain | 8/14/2017 | 38.00 | AWM2-CF-M24 | 9/1/2017 | 2.03 |
| AG Wright | AWM-CS-SC1A | Classroom Sink | 8/14/2017 | 299.00 | AWM2-CS2-SC1A | 9/1/2017 | 128.00 |
| AG Wright | AWM-CS-SC1B | Classroom Sink | 8/14/2017 | 23.20 | AWM2-CS-SC1B | 9/1/2017 | 24.90 |
| AG Wright | AWM-CS-SC1C | Classroom Sink | 8/14/2017 | 64.00 | AWM2-CS-SC1C | 9/1/2017 | 16.20 |
| AG Wright | AWM-CS-HL1 | Classroom Sink | 8/14/2017 | 400.00 | AWM2-CS-HL1 | 9/1/2017 | 434.00 |
| AG Wright | AWM-CS-SC4A | Classroom Sink | 8/14/2017 | 819.00 | AWM2-CS-SC4A | 9/1/2017 | 265.00 |
| AG Wright | AWM-CS-SC4B | Classroom Sink | 8/14/2017 | 16.00 | AWM2-CS-SC4B | 9/1/2017 | 14.50 |
| AG Wright | AWM-CS-SC3A | Classroom Sink | 8/14/2017 | 612.00 | AWM2-CS-SC3A | 9/1/2017 | 211.00 |
| AG Wright | AWM-CS-SC3B | Classroom Sink | 8/14/2017 | 36.00 | AWM2-CS-SC3B | 9/1/2017 | 21.00 |
| AG Wright | AWM-CS-SC3C | Classroom Sink | 8/14/2017 | 36.60 | AWM2-CS-SC3C | 9/1/2017 | 74.40 |
| AG Wright | AWM-CS-SC2A | Classroom Sink | 8/14/2017 | 1510.00 | AWM2-CS-SC2A | 9/1/2017 | 535.00 |
| AG Wright | AWM-CS-SC2B | Classroom Sink | 8/14/2017 | 24.00 | AWM2-CS-SC2B | 9/1/2017 | 25.90 |
| AG Wright | AWM-CS-SC34 | Classroom Sink | 8/14/2017 | 125.00 | AWM2-CS-SC34 | 9/1/2017 | 36.10 |
| AG Wright | AWM-CS-SC12 | Classroom Sink | 8/14/2017 | 49.80 | AWM2-CS-SC12 | 9/1/2017 | 26.50 |
| AG Wright | AWM-CS-ART | Classroom Sink | 8/14/2017 | 90.50 | AWM2-CS-ART | 9/1/2017 | 7.23 |
| AG Wright | AWM-CS-PREP1 | Classroom Sink | 8/14/2017 | 49.40 | AWM2-CS-PREP1 | 9/1/2017 | 21.40 |
| AG Wright | AWM-SC8A | Classroom Sink | 8/14/2017 | 19.20 | AWM2-CS-SC8A | 9/1/2017 | 9.99 |
| AG Wright | AWM-SC8B | Classroom Sink | 8/14/2017 | 16.20 | AWM2-CS-SC8B | 9/1/2017 | 9.44 |
| AG Wright | AWM-SC7A | Classroom Sink | 8/14/2017 | 37.10 | AWM2-CS-SC7A | 9/1/2017 | 5.20 |
| AG Wright | AWM-SC7C | Classroom Sink | 8/14/2017 | 75.40 | AWM2-CS-SC7C | 9/1/2017 | 19.00 |
| AG Wright | AWM-CWF-CAF | Cafeteria Water Fountain | 8/14/2017 | 22.70 | Sample Not Collected | 9/1/2017 | Not Functioning |
| Drew MS | EDM-BS-GL4 | Bathroom Sink | 8/15/2017 | 374.00 | EDM2-BS-GL4 | 9/1/2017 | 92.60 |
| Drew MS | EDM-BS-KT1 | Bathroom Sink | 8/15/2017 | 18.20 | EDM2-BS-KT1 | 9/1/2017 | 5.79 |
| Drew MS | EDM-CS1-RM21 | Classroom Sink | 8/15/2017 | 15.60 | EDM2-CS1-RM21 | 9/1/2017 | 3.50 |
| Drew MS | EDM-CS2-RM21 | Classroom Sink | 8/15/2017 | 36.20 | EDM2-CS2-RM22 | 9/1/2017 | 2.00 |
| Falmouth ES | FME-BS-BU2 | Bathroom Sink | 8/14/2017 | 23.70 | FME2-BS-BU2 | 9/1/2017 | <1.00 |
| Falmouth ES | FME-CF-RM106 | Classroom Fountain | 8/14/2017 | 93.40 | FME2-CF-RM106 | 9/1/2017 | 1.87 |
| Falmouth ES | FME-CF-RM8 | Classroom Fountain | 8/14/2017 | 123.00 | FME2-CF-RM8 | 9/1/2017 | 1.29 |
| Falmouth ES | FME-KS-BR1 | Kitchen Sink | 8/14/2017 | 16.00 | FME2-KS-BR1 | 9/1/2017 | 3.17 |
| Gari Melchers | GMC-BS-TYBM | Bathroom Sink | 8/16/2017 | 24.20 | GMC2-BS-TYBM | 9/1/2017 | 1.43 |
| Gari Melchers | GMC-CS-RM015 | Classroom Sink | 8/16/2017 | 51.00 | GMC2-CS-RM105 | 9/1/2017 | 8.39 |
| Gari Melchers | GMC-BS-W8 | Bathroom Sink | 8/16/2017 | 16.40 | GMC2-BS-W8 | 9/1/2017 | 1.84 |
| Gari Melchers | GMC-HF-EX | Exterior Walkway Fountain | 8/16/2017 | 30.10 | GMC2-HF-EX | 9/1/2017 | 18.10 |
| Gari Melchers | GMC-KS-KT4 | Kitchen Sink | 8/16/2017 | 28.70 | GMC2-KS-KT4 | 9/1/2017 | 1.06 |
| Garrisonville ES | GVE-BS-IFL-NB | Bathroom Sink | 8/14/2017 | 15.80 | GVE2-BS-1FL-NB | 9/1/2017 | 13.40 |
| Garrisonville ES | GVE-CF-RME19 | Classroom Fountain | 8/14/2017 | 316.00 | GVE2-CF-RME19 | 9/1/2017 | 1.27 |
| Garrisonville ES | GVE-CF-RME18 | Classroom Fountain | 8/14/2017 | 50.50 | GVE2-CF-RME18 | 9/1/2017 | 6.69 |
| Garrisonville ES | GVE-CF-RME30 | Classroom Fountain | 8/14/2017 | 21.00 | GVE2-CF-RME30 | 9/1/2017 | 11.10 |
| Garrisonville ES | GVE-CF-RME27 | Classroom Fountain | 8/14/2017 | 26.90 | GVE2-CF-RME27 | 9/1/2017 | 1.47 |
| Garrisonville ES | GVE-CF-RME26 | Classroom Fountain | 8/14/2017 | 115.00 | GVE2-CF-RME26 | 9/1/2017 | 3.10 |
| Garrisonville ES | GVE-CF-RME25 | Classroom Fountain | 8/14/2017 | 37.10 | GVE2-CF-RME25 | 9/1/2017 | 8.12 |
| Garrisonville ES | GVE-CF-RME23 | Classroom Fountain | 8/14/2017 | 238.00 | GVE2-CF-RME23 | 9/1/2017 | 1.38 |
| Garrisonville ES | GVE-CF-RME22 | Classroom Fountain | 8/14/2017 | 19.70 | GVE2-CF-RME22 | 9/1/2017 | 7.43 |
| Garrisonville ES | GVE-CF-E16 | Classroom Fountain | 8/14/2017 | 17.10 | GVE2-CF-RME16 | 9/1/2017 | 4.28 |
| Garrisonville ES | GVE-CF-E11 | Classroom Fountain | 8/14/2017 | 42.40 | GVE2-CF-RME11 | 9/1/2017 | 1.56 |
| Garrisonville ES | GVE-CF-E7 | Classroom Fountain | 8/14/2017 | 22.90 | GVE2-CF-RME7 | 9/1/2017 | 16.90 |

| School ID | Sample Name | Sample Type | First Round Sampling Date (No Pre-Stagnation Flushing, Followed by Initial First Draw Sample) | First Round Results (ppb) (ppb = µg/L) | Sample Name | Second Round Sampling Date (1 hour Flushing, Followed by Initial First Draw Sample) | Second Round Results (ppb) (ppb = µg/L) |
|--------------------------|------------------------|-------------------------|--|---|--------------------------|---|--|
| Garrisonville ES | GVE-KS-IFL-OF1 | Kitchen Sink | 8/14/2017 | 43.70 | GVE2-KS-1FL-OF1 | 9/1/2017 | 6.87 |
| Grafton ES | GRE-BS-BW1 | Bathroom Sink | 8/15/2017 | 54.40 | GRE2-BS-BW1 | 9/1/2017 | 2.66 |
| Grafton ES | GRE-CF-RM107 | Classroom Fountain | 8/15/2017 | 17.90 | GRE2-CF-RM107 | 9/1/2017 | <1.00 |
| Grafton ES | GRE-KS-BR1 | Kitchen Sink | 8/15/2017 | 17.00 | GRE2-KS-BR1 | 9/1/2017 | 4.40 |
| Grafton ES | GRE-KS-KT2 | Kitchen Sink | 8/15/2017 | 30.40 | GRE2-KS-KT2 | 9/1/2017 | 5.02 |
| Hartwood ES | HWE-CS1-RMART | Classroom Sink | 8/16/2017 | 19.40 | HWE2-CS1-RMART | 9/1/2017 | 4.02 |
| Hartwood ES | HWE-CS2-RMART | Classroom Sink | 8/16/2017 | 39.80 | HWE2-CS2-RMART | 9/1/2017 | 3.93 |
| Hartwood ES | HWE-CS-HL3OF | Classroom Sink | 8/16/2017 | 40.70 | HWE2-CS-HL3OF | 9/1/2017 | 116.00 |
| North Stafford HS | NSH-BS-RM117 | Bathroom Sink | 8/15/2017 | 29.30 | NSH2-BS-RM117 | 9/1/2017 | 22.10 |
| North Stafford HS | NSH-BS-RM527-BM | Bathroom Sink | 8/15/2017 | 148.00 | NSH2-BS-RM527-BM | 9/1/2017 | 9.85 |
| North Stafford HS | NSH-BS-HIIFBM | Bathroom Sink | 8/15/2017 | 36.70 | NSH2-BS-H11FBM | 9/1/2017 | 1.43 |
| North Stafford HS | NSH-BS-BLR-B | Bathroom Sink | 8/16/2017 | 46.60 | NSH2-BS-BLR-B | 9/1/2017 | <1.00 |
| North Stafford HS | NSH-CS-RM502A-5 | Classroom Sink | 8/15/2017 | 262.00 | NSH2-CS-RM502A-5 | 9/1/2017 | 16.50 |
| North Stafford HS | NSH-CS-RM505 | Classroom Sink | 8/15/2017 | 25.60 | NSH2-CS-RM505 | 9/1/2017 | 6.23 |
| North Stafford HS | NSH-CS-RM514 | Classroom Sink | 8/15/2017 | 33.90 | NSH2-CS-RM514 | 9/1/2017 | 10.80 |
| North Stafford HS | NSH-CS-RM524 | Classroom Sink | 8/15/2017 | 28.80 | NSH2-CS-RM524 | 9/1/2017 | 1.85 |
| North Stafford HS | NSH-CS-RM525 | Classroom Sink | 8/15/2017 | 44.50 | NSH2-CS-RM525 | 9/1/2017 | 19.40 |
| North Stafford HS | NSH-CS-RM526 | Classroom Sink | 8/15/2017 | 50.10 | NSH2-CS-RM526 | 9/1/2017 | 21.80 |
| North Stafford HS | NSH-CS-RM533-1 | Classroom Sink | 8/15/2017 | 22.50 | NSH2-CS-RM533-1 | 9/1/2017 | 2.54 |
| North Stafford HS | NSH-CS-RM542 | Classroom Sink | 8/15/2017 | 131.00 | NSH2-CS-RM542 | 9/1/2017 | 23.00 |
| North Stafford HS | NSH-CF-RM534 | Classroom Sink | 8/15/2017 | 85.20 | NSH2-CF-RM534 | 9/1/2017 | 178.00 |
| North Stafford HS | NSH-CS-RM538-ST | Classroom Sink | 8/15/2017 | 562.00 | NSH2-CS-RM538-ST | 9/1/2017 | 136.00 |
| North Stafford HS | NSH-CS-RM433-1 | Classroom Sink | 8/15/2017 | 1960.00 | NSH2-CS-RM433-1 | 9/1/2017 | 310.00 |
| North Stafford HS | NSH-CS-RM303-A | Classroom Sink | 8/15/2017 | 135.00 | NSH2-CS-RM303-A | 9/1/2017 | 2380.00 |
| North Stafford HS | NSH-CS-RM303-C | Classroom Sink | 8/15/2017 | 31.90 | NSH2-CS-RM303-C | 9/1/2017 | 14.30 |
| North Stafford HS | NSH-CS-PREP | Classroom Sink | 8/15/2017 | 17.40 | NSH2-CS-PREP | 9/1/2017 | 66.40 |
| North Stafford HS | NSH-CS-RM302-2 | Classroom Sink | 8/15/2017 | 278.00 | NSH2-CS-RM302-2 | 9/1/2017 | 30.20 |
| North Stafford HS | NSH-CS-RM321-A | Classroom Sink | 8/15/2017 | 33.80 | NSH2-CS-RM321-A | 9/1/2017 | 14.20 |
| North Stafford HS | NSH-CS-PREP-321 | Classroom Sink | 8/15/2017 | 21.50 | NSH2-CS-PREP-321 | 9/1/2017 | 7.74 |
| North Stafford HS | NSH-CS-RM319-A | Classroom Sink | 8/15/2017 | 29.10 | NSH2-CS-RM319-A | 9/1/2017 | 3.42 |
| North Stafford HS | NSH-CS-RM325-A | Classroom Sink | 8/16/2017 | 41.20 | NSH2-CS-RM325-A | 9/1/2017 | 14.70 |
| North Stafford HS | NSH-CS-RM320-A | Classroom Sink | 8/16/2017 | 17.30 | NSH2-CS-RM320-A | 9/1/2017 | 33.60 |
| North Stafford HS | NSH-CS-RM320-C | Classroom Sink | 8/16/2017 | 17.90 | NSH2-CS-RM320-C | 9/1/2017 | 6.66 |
| North Stafford HS | NSH-CS-320-318 | Classroom Sink | 8/16/2017 | 15.10 | NSH2-CS-320-318 | 9/1/2017 | 8.43 |
| North Stafford HS | NSH-CS-324-322 | Classroom Sink | 8/16/2017 | 240.00 | NSH2-CS-RM324-322 | 9/1/2017 | 133.00 |
| North Stafford HS | NSH-CS-RM322-A | Classroom Sink | 8/16/2017 | 15.80 | NSH2-CS-RM322-A | 9/1/2017 | 88.90 |
| North Stafford HS | NSH-HF-GLR | Hallway Fountain | 8/16/2017 | 482.00 | NSH2-HF-GLR | 9/1/2017 | 373.00 |
| North Stafford HS | NSH-S-CON1 | Sink | 8/16/2017 | 15.60 | NSH2-S-CON1 | 9/1/2017 | 7.11 |
| North Stafford HS | NSH-S-AUD | Sink | 8/16/2017 | 40.20 | NSH2-S-AUD | 9/1/2017 | 1.65 |
| Stafford ES | STE-CS-RM13 | Classroom Sink | 8/17/2017 | 24.50 | STE2-CS-RM13 | 9/1/2017 | 6.41 |
| Widewater ES | WWE-BS-RM28 | Bathroom Sink | 8/16/2017 | 16.90 | WWE2-BS-RM28 | 9/1/2017 | 4.00 |
| Widewater ES | WWE-BS-H4BM | Bathroom Sink | 8/16/2017 | 15.60 | WWE2-BS-H4BM | 9/1/2017 | 5.05 |
| Widewater ES | WWE-BS-RM34 | Bathroom Sink | 8/16/2017 | 26.60 | WWE2-BS-RM34 | 9/1/2017 | 6.21 |
| Ferry Farm ES | FFE-CF-RM105 | Classroom Fountain | 8/21/2017 | 16.70 | FFE2-CF-RM105 | 9/1/2017 | <1.00 |